

**Diamond Estates Subdivision**  
**DRAINAGE CALCULATIONS – SUMMARY**  
**2/8/2023**

**DESCRIPTION OF PROJECT**

Diamond Estates Subdivision is an approximately 14.90 Acre development located in the City of Bryant, Arkansas, north of Highway 5 and east of Midland Road. There is one large drainage basin that flows to north. Discharges will not be detained and in-lieu-fee will be provided for this detention.

Stormwater Calculations were prepared with the intent to comply with the City of Bryant's Drainage Code. Hydraulic calculations were made using the Rational Method. Design frequencies were analyzed for 2, 5, 10, 25, 50, and 100 year return periods.

These calculations are divided into the following sections:

**Summary of Drainage Basins**

**Summary of Inlets**

**Summary of Pipes**

**Appendices**

Exhibit A – Pre-Development Drainage Basins

Exhibit B – Post-Development Drainage Basins

**Diamond Estates Subdivision**  
**DRAINAGE CALCULATIONS – SUMMARY**  
**2/8/2023**

**SUMMARY OF DRAINAGE BASINS**

There is only a drainage basin that flows to north. This discharge will not be captured. In-Lieu-fee is provided for detention. In-lieu-fee calculation is prepared based on the City of Bryant's Drainage Code.

**SUMMARY OF INLETS**

On the drainage plan you will see labels for all of the inlets for these calculations. The flows shown are for the 10-year return storm. The distance from the face of the curb to the center of the street is 15 feet.

**SUMMARY OF PIPES**

All pipes used in this project are HDPE or RCP. Therefore, a manning's of 0.012 was used on all pipes in the analysis.

**Stormwater Calcs - Diamond Estates Subdivision  
Using Rational Method**

Pre-development

**Calculated Tc values - Drainage Basin 1, 2 & 3**

$$T_c = \frac{56 * L^{.6} * n^{.6}}{i^{.4} * S^{.3}} \text{ seconds}$$

L1 = 485 feet  
 n1 = 0.05 Sluggish Reaches  
 S1 = 0.031 ft/ft  
 I<sub>assumed</sub> = 7.20 inches  
 T<sub>c</sub><sub>calculated</sub> = 488 seconds  
 T<sub>c</sub><sub>calculated</sub> = 8.14 minutes

T<sub>c</sub> = 8.14 minutes  
 I = 7.20 inches

Use T<sub>c</sub> = **8.15** minutes

T<sub>c</sub> for 25-yr Storm from Exhibit 400-1 of Bryant Drainage Manual  
 i for 25-yr Storm from Exhibit 400-1 of Bryant Drainage Manual

I <sub>100</sub> =	9 Inches	I <sub>10</sub> =	6.5 Inches
I <sub>50</sub> =	8 Inches	I <sub>5</sub> =	5.8 Inches
I <sub>25</sub> =	7.20 Inches	I <sub>2</sub> =	5 Inches

**Stormwater Calcs - Diamond Estates Subdivision**  
**Using Rational Method**

Post-development

**Calculated Tc values - Drainage Basin 1, 2 & 3**

$$T_c = \frac{56 * L^{.6} * n^{.6}}{i^{.4} * S^{.3}} \text{ seconds}$$

L1 = 285 feet  
 n1 = 0.02 Clean, recently constructed  
 S1 = 0.031 ft/ft  
 I<sub>assumed</sub> = 8.40 inches  
 T<sub>Ccalculated</sub> = 193 seconds  
 T<sub>Ccalculated</sub> = 3.21 minutes

Tc = 3.21 minutes  
 I = 8.40 inches

Use Tc = **5.00** minutes

Tc for 25-yr Storm from Exhibit 400-1 of Bryant Drainage Manual  
 i for 25-yr Storm from Exhibit 400-1 of Bryant Drainage Manual

I <sub>100</sub> =	10 Inches	I <sub>10</sub> =	7.2 Inches
I <sub>50</sub> =	9.2 Inches	I <sub>5</sub> =	6.5 Inches
I <sub>25</sub> =	8.40 Inches	I <sub>2</sub> =	5.6 Inches

**Stormwater Calcs - Diamond Estates Subdivision  
using Rational Method**

**Pre-development**

**Calculated C values - Drainage Basin 1**

	<b>Area</b>	<b>C<sub>100</sub></b>	<b>C<sub>50</sub></b>	<b>C<sub>25</sub></b>	<b>C<sub>10</sub></b>	<b>C<sub>5</sub></b>	<b>C<sub>2</sub></b>
Greenspace	14.90	0.47	0.43	0.4	0.36	0.34	0.31
<b>Total Area =</b>	<b>14.90</b>	<b>0.47</b>	<b>0.43</b>	<b>0.40</b>	<b>0.36</b>	<b>0.34</b>	<b>0.31</b>

(C values taken from Table 400-2 of City of Bryant Drainage Manual)

Forrest/Woodlands, Average 2-7%

Stormwater Calcs - Diamond Estates Subdivision  
 using Rational Method

Post-development

Calculated C values - Drainage Basin 1

	Area	C <sub>100</sub>	C <sub>50</sub>	C <sub>25</sub>	C <sub>10</sub>	C <sub>5</sub>	C <sub>2</sub>
Residential	14.90	0.7	0.65	0.6	0.5	0.4	0.35
<b>Total Area =</b>	<b>14.90</b>	<b>0.70</b>	<b>0.65</b>	<b>0.60</b>	<b>0.50</b>	<b>0.40</b>	<b>0.35</b>

(C values taken from Table 2.1 of City of Little Rock Drainage Manual)

Single Family, Residential

Stormwater Calcs - Diamond Estates Subdivision  
using Rational Method

Pre-development

Drainage Basin 1

Q <sub>100</sub> = 63.03 CFS	Q <sub>60</sub> = 51.26 CFS	Q <sub>25</sub> = 42.91 CFS	Q <sub>10</sub> = 34.87 CFS	Q <sub>5</sub> = 29.38 CFS	Q <sub>2</sub> = 23.10 CFS
c = 0.47	c = 0.43	c = 0.40	c = 0.36	c = 0.34	c = 0.31
i = 9.00 in/hr	i = 8.00 in/hr	i = 7.20 in/hr	i = 6.50 in/hr	i = 5.80 in/hr	i = 5.00 in/hr
A = 14.90 acres	A = 14.90 acres	A = 14.90 acres	A = 14.90 acres	A = 14.90 acres	A = 14.90 acres

Post-development

Drainage Basin 1

Q <sub>100</sub> = 104.30 CFS	Q <sub>60</sub> = 89.10 CFS	Q <sub>25</sub> = 75.10 CFS	Q <sub>10</sub> = 53.64 CFS	Q <sub>5</sub> = 38.74 CFS	Q <sub>2</sub> = 29.20 CFS
c = 0.70	c = 0.65	c = 0.60	c = 0.50	c = 0.40	c = 0.35
i = 10.00 in/hr	i = 9.20 in/hr	i = 8.40 in/hr	i = 7.20 in/hr	i = 6.50 in/hr	i = 5.60 in/hr
A = 14.90 acres	A = 14.90 acres	A = 14.90 acres	A = 14.90 acres	A = 14.90 acres	A = 14.90 acres

Detention Volume

Pond-1 for Q100	
Cundev =	0.47
lundev =	9.00 in/hr
Cdev =	0.70
ldev =	10.00 in/hr
R =	2.77
A =	14.90 acres
Tc =	5.00 minutes
	60 sec/min
Detention Volume =	12,382 cubic feet

$$R = (Cdev * ldev) - (Cundev * lundev)$$

$$Detention Volume = R * A * Tc * 60$$

**Stormwater Calcs - Diamond Estates Subdivision  
using Rational Method**


Total Detention= 12381.90 cubic feet

**In-Lieu Detention (\$10,000/ac-ft) Ratio = Vol (100-yr)/43,560 sq ft /ac**

In-Lieu-Fee = 0.284249 ac-ft  
= **\$2,842.49**

**Note - \$500 minimum**







<p><b>FOR USE &amp; BENEFIT:</b> <b>DIAMOND DEVELOPMENT</b></p>	<p><b>PRELIMINARY</b></p>	<p>CONTENTS: <b>PRE DEVELOPED BASIN</b></p>	<p>PROJECT NO: <b>21206</b></p>	<p>DATE: <b>FEB 2023</b></p>	<p>SHEET NO: <b>2.0</b></p>	
	<p><b>PRELIMINARY</b></p>	<p>PROJECT NO: <b>21206</b></p>	<p>DATE: <b>FEB 2023</b></p>	<p>SHEET NO: <b>2.0</b></p>		
	<p><b>FOR USE &amp; BENEFIT:</b> <b>DIAMOND DEVELOPMENT</b></p>	<p><b>PRELIMINARY</b></p>	<p>CONTENTS: <b>PRE DEVELOPED BASIN</b></p>	<p>PROJECT NO: <b>21206</b></p>	<p>DATE: <b>FEB 2023</b></p>	<p>SHEET NO: <b>2.0</b></p>
	<p><b>FOR USE &amp; BENEFIT:</b> <b>DIAMOND DEVELOPMENT</b></p>	<p><b>PRELIMINARY</b></p>	<p>CONTENTS: <b>PRE DEVELOPED BASIN</b></p>	<p>PROJECT NO: <b>21206</b></p>	<p>DATE: <b>FEB 2023</b></p>	<p>SHEET NO: <b>2.0</b></p>

REVISION	DATE	BY

**GNE** Designing our client's success  
**GarNat Engineering, LLC**  
 P.O. Box 116 (72018) Ph (501) 408-4650  
 2909 Military Road Fx (888) 900-3068  
 Benton, AR 72015 gmatengineer@gmail.com

\Projects\2023\Project\21206\Diamond\Diamond.dwg Rev. 2. Mail Area Property\Diamond\Diamond.dwg Rev. 2.1208 8/26/2023 2:05:59 PM



BY	REVISION	DATE

**GNE** Designing our client's success  
**GarNat Engineering, LLC**  
 P.O. Box 116 (72018)  
 2909 Military Road  
 Benton, AR 72015  
 Ph (501) 408-4650  
 Fx (888) 900-3068  
 gnatengineer@gmail.com

**FOR USE & BENEFIT:**  
**DIAMOND DEVELOPMENT**

**PRELIMINARY**

CONTENTS:	<b>POST DEVELOPED BASIN</b>
PROJECT NO:	<b>21206</b>
DATE:	<b>FEB 2023</b>
SHEET NO:	<b>3.0</b>

\\projects\2023\Projects\21206\Diamond\Diamond\Drawings\Diamond\Diamond\21206\_0303.dwg

**Stormwater Calcs - Diamond Estates Subdivision**  
**Using Rational Method**

Post-development Basin

**Calculated Tc values - Drainage Basin CI-1**

$$T_c = \frac{56 * L^{.6} * n^{.6}}{i^{.4} * S^{.3}} \text{ seconds}$$

L1 =	700	feet
n1 =	0.013	Smooth Concrete/Asphalt
S1 =	0.031	ft/ft
I <sub>assumed</sub> =	7.20	inches
T <sub>c</sub> <sub>calculated</sub>	271	seconds
T <sub>c</sub> <sub>calculated</sub>	4.52	minutes
Tc =	4.52	minutes
I =	7.20	inches
Use Tc =	<b>5.00</b>	minutes

Stormwater Calcs - Diamond Estates Subdivision  
 using Rational Method  
 POST-DEV C VALUES

CI-1					
Area	C <sub>10</sub>	C <sub>25</sub>	C <sub>100</sub>	(C values taken from Table 400-2 of City of Bryant Drainage Manual)	
0.80	0.5	0.6	0.7	Residential	
<b>Total Area = 0.80</b>	<b>0.50</b>	<b>0.60</b>	<b>0.70</b>		

CI-2					
Area	C <sub>10</sub>	C <sub>25</sub>	C <sub>100</sub>	(C values taken from Table 400-2 of City of Bryant Drainage Manual)	
0.16	0.81	0.86	0.95	Asphalt	
<b>Total Area = 0.16</b>	<b>0.81</b>	<b>0.86</b>	<b>0.95</b>		

CI-3					
Area	C <sub>10</sub>	C <sub>25</sub>	C <sub>100</sub>	(C values taken from Table 400-2 of City of Bryant Drainage Manual)	
	0.66	0.5	0.6	0.7	Residential
<b>Total Area =</b>	<b>0.66</b>	<b>0.50</b>	<b>0.60</b>	<b>0.70</b>	

CI-4					
Area	C <sub>10</sub>	C <sub>25</sub>	C <sub>100</sub>	(C values taken from Table 400-2 of City of Bryant Drainage Manual)	
	0.14	0.81	0.86	0.95	Asphalt
<b>Total Area =</b>	<b>0.14</b>	<b>0.81</b>	<b>0.86</b>	<b>0.95</b>	

CI-5					
Area	C <sub>10</sub>	C <sub>25</sub>	C <sub>100</sub>	(C values taken from Table 400-2 of City of Bryant Drainage Manual)	
	0.58	0.5	0.6	0.7	Residential
<b>Total Area =</b>	<b>0.58</b>	<b>0.50</b>	<b>0.60</b>	<b>0.70</b>	

CI-6					
Area	C <sub>10</sub>	C <sub>25</sub>	C <sub>100</sub>	(C values taken from Table 400-2 of City of Bryant Drainage Manual)	
	0.11	0.81	0.86	0.95	Asphalt
<b>Total Area =</b>	<b>0.11</b>	<b>0.81</b>	<b>0.86</b>	<b>0.95</b>	

JB-2					
Area	C <sub>10</sub>	C <sub>25</sub>	C <sub>100</sub>	(C values taken from Table 400-2 of City of Bryant Drainage Manual)	
	0.01	0.5	0.6	0.7	Residential
<b>Total Area =</b>	<b>0.01</b>	<b>0.50</b>	<b>0.60</b>	<b>0.70</b>	

CI-8					
Area	C <sub>10</sub>	C <sub>25</sub>	C <sub>100</sub>	(C values taken from Table 400-2 of City of Bryant Drainage Manual)	
	0.66	0.5	0.6	0.7	Residential
<b>Total Area =</b>	<b>0.66</b>	<b>0.50</b>	<b>0.60</b>	<b>0.70</b>	

CI-9					
Area	C <sub>10</sub>	C <sub>25</sub>	C <sub>100</sub>	(C values taken from Table 400-2 of City of Bryant Drainage Manual)	
	0.12	0.81	0.86	0.95	Asphalt
<b>Total Area =</b>	<b>0.12</b>	<b>0.81</b>	<b>0.86</b>	<b>0.95</b>	

CI-10					
Area	C <sub>10</sub>	C <sub>25</sub>	C <sub>100</sub>	(C values taken from Table 400-2 of City of Bryant Drainage Manual)	
	1.75	0.5	0.6	0.7	Residential
<b>Total Area =</b>	<b>1.75</b>	<b>0.50</b>	<b>0.60</b>	<b>0.70</b>	

CI-11					
Area	C <sub>10</sub>	C <sub>25</sub>	C <sub>100</sub>	(C values taken from Table 400-2 of City of Bryant Drainage Manual)	
	0.30	0.81	0.86	0.95	Asphalt
<b>Total Area =</b>	<b>0.30</b>	<b>0.81</b>	<b>0.86</b>	<b>0.95</b>	

CI-12					
Area	C <sub>10</sub>	C <sub>25</sub>	C <sub>100</sub>	(C values taken from Table 400-2 of City of Bryant Drainage Manual)	
	0.50	0.5	0.6	0.7	Residential
<b>Total Area =</b>	<b>0.50</b>	<b>0.50</b>	<b>0.60</b>	<b>0.70</b>	

CI-13					
Area	C <sub>10</sub>	C <sub>25</sub>	C <sub>100</sub>	(C values taken from Table 400-2 of City of Bryant Drainage Manual)	
	0.12	0.81	0.86	0.95	Asphalt
<b>Total Area =</b>	<b>0.12</b>	<b>0.81</b>	<b>0.86</b>	<b>0.95</b>	

CI-14					
Area	C <sub>10</sub>	C <sub>25</sub>	C <sub>100</sub>	(C values taken from Table 400-2 of City of Bryant Drainage Manual)	
	0.09	0.81	0.86	0.95	Asphalt
<b>Total Area =</b>	<b>0.09</b>	<b>0.81</b>	<b>0.86</b>	<b>0.95</b>	

CI-15					
Area	C <sub>10</sub>	C <sub>25</sub>	C <sub>100</sub>	(C values taken from Table 400-2 of City of Bryant Drainage Manual)	
	0.32	0.81	0.86	0.95	Asphalt
<b>Total Area =</b>	<b>0.32</b>	<b>0.81</b>	<b>0.86</b>	<b>0.95</b>	

CI-16					
Area	C <sub>10</sub>	C <sub>25</sub>	C <sub>100</sub>	(C values taken from Table 400-2 of City of Bryant Drainage Manual)	
	0.56	0.81	0.86	0.95	Asphalt
<b>Total Area =</b>	<b>0.56</b>	<b>0.81</b>	<b>0.86</b>	<b>0.95</b>	

JB-1					
Area	C <sub>10</sub>	C <sub>25</sub>	C <sub>100</sub>	(C values taken from Table 400-2 of City of Bryant Drainage Manual)	
	1.37	0.5	0.6	0.7	Residential
<b>Total Area =</b>	<b>1.37</b>	<b>0.50</b>	<b>0.60</b>	<b>0.70</b>	



**Stormwater Calcs - Diamond Estates Subdivision**  
**using Rational Method**  
**Post Development Flowrates**

CI-1	$Q_{10} =$	2.88 CFS
	$c =$	0.50
	$i =$	7.20 in/hr
	$A =$	0.80 acres

CI-2	$Q_{10} =$	0.93 CFS
	$c =$	0.81
	$i =$	7.20 in/hr
	$A =$	0.16 acres

CI-3	$Q_{10} =$	2.38 CFS
	$c =$	0.50
	$i =$	7.20 in/hr
	$A =$	0.66 acres

CI-4

$Q_{10} =$  0.82 CFS  
 $c =$  0.81  
 $i =$  7.20 in/hr  
 $A =$  0.14 acres

CI-5

$Q_{10} =$  2.09 CFS  
 $c =$  0.50  
 $i =$  7.20 in/hr  
 $A =$  0.58 acres

CI-6

$Q_{10} =$  0.64 CFS  
 $c =$  0.81  
 $i =$  7.20 in/hr  
 $A =$  0.11 acres

CI-7

$Q_{10} =$  0.04 CFS  
 $c =$  0.50  
 $i =$  7.20 in/hr  
 $A =$  0.01 acres

CI-8

$Q_{10} =$  2.38 CFS  
 $c =$  0.50  
 $i =$  7.20 in/hr  
 $A =$  0.66 acres

CI-9

$Q_{10} =$  0.70 CFS  
 $c =$  0.81  
 $i =$  7.20 in/hr  
 $A =$  0.12 acres

CI-10

$Q_{10} =$  6.30 CFS  
 $c =$  0.50  
 $i =$  7.20 in/hr  
 $A =$  1.75 acres

CI-11

$Q_{10} =$  1.75 CFS  
 $c =$  0.81  
 $i =$  7.20 in/hr  
 $A =$  0.30 acres

CI-12

$Q_{10} =$  1.80 CFS  
 $c =$  0.50  
 $i =$  7.20 in/hr  
 $A =$  0.50 acres

CI-13

$Q_{10} =$  0.70 CFS  
 $c =$  0.81  
 $i =$  7.20 in/hr  
 $A =$  0.12 acres

CI-14

$Q_{10} =$  0.52 CFS  
 $c =$  0.81  
 $i =$  7.20 in/hr  
 $A =$  0.09 acres

CI-15

$Q_{10} =$  1.87 CFS  
 $c =$  0.81  
 $i =$  7.20 in/hr  
 $A =$  0.32 acres

CI-16

$Q_{10} =$  3.27 CFS  
 $c =$  0.81  
 $i =$  7.20 in/hr  
 $A =$  0.56 acres

JB-1

$Q_{10} =$  4.93 CFS  
 $c =$  0.50  
 $i =$  7.20 in/hr  
 $A =$  1.37 acres

## Diamond Estates Subdivision - GUTTER SPREAD 10-YR STORM

### CI-1

	T=	$\left( \frac{Q * n}{k_u * S_x^{1.67} * S_L^{0.5}} \right)^{.375}$	
Q	2.88 cfs		Q= Flowrate(cfs)
n	0.012		n=manning's number
k <sub>u</sub>	0.56		k=0.56
S <sub>x</sub>	0.028		S <sub>x</sub> = cross slope
S <sub>L</sub>	0.031		S <sub>L</sub> = longitudinal slope
T	<u>6.33</u> ft		T= Gutter Spread

### CI-2

	T=	$\left( \frac{Q * n}{k_u * S_x^{1.67} * S_L^{0.5}} \right)^{.375}$	
Q	0.93 cfs		
n	0.012		
k <sub>u</sub>	0.56		
S <sub>x</sub>	0.03		
S <sub>L</sub>	0.017		
T	<u>4.45</u> ft		

### CI-3

	T=	$\left( \frac{Q * n}{k_u * S_x^{1.67} * S_L^{0.5}} \right)^{.375}$	
Q	2.38 cfs		
n	0.012		
k <sub>u</sub>	0.56		
S <sub>x</sub>	0.028		
S <sub>L</sub>	0.03		
T	<u>6.01</u> ft		

**CI-4**

$$T = \left( \frac{Q \cdot n}{k_u \cdot S_x^{1.67} \cdot S_L^{0.5}} \right)^{.375}$$

Q	0.82 cfs
n	0.012
k <sub>u</sub>	0.56
S <sub>x</sub>	0.03
S <sub>L</sub>	0.03
T	<b><u>3.85</u></b> ft

**CI-5**

$$T = \left( \frac{Q \cdot n}{k_u \cdot S_x^{1.67} \cdot S_L^{0.5}} \right)^{.375}$$

Q	2.09 cfs
n	0.012
k <sub>u</sub>	0.56
S <sub>x</sub>	0.028
S <sub>L</sub>	0.03
T	<b><u>5.65</u></b> ft

**CI-6**

$$T = \left( \frac{Q \cdot n}{k_u \cdot S_x^{1.67} \cdot S_L^{0.5}} \right)^{.375}$$

Q	0.64 cfs
n	0.012
k <sub>u</sub>	0.56
S <sub>x</sub>	0.03
S <sub>L</sub>	0.03
T	<b><u>3.52</u></b> ft

**CI-7**

$$T = \left( \frac{Q \cdot n}{k_u \cdot S_x^{1.67} \cdot S_L^{0.5}} \right)^{.375}$$

Q	0.04 cfs
n	0.012
k <sub>u</sub>	0.56
S <sub>x</sub>	0.03
S <sub>L</sub>	0.03
T	<b><u>1.18</u></b> ft

**CI-8**

$$T = \left( \frac{Q \cdot n}{k_u \cdot S_x^{1.67} \cdot S_L^{0.5}} \right)^{.375}$$

Q	2.38 cfs
n	0.012
$k_u$	0.56
$S_x$	0.028
$S_L$	0.03
T	<b><u>5.93</u></b> ft

**CI-9**

$$T = \left( \frac{Q \cdot n}{k_u \cdot S_x^{1.67} \cdot S_L^{0.5}} \right)^{.375}$$

Q	0.70 cfs
n	0.012
$k_u$	0.56
$S_x$	0.028
$S_L$	0.03
T	<b><u>3.75</u></b> ft

**CI-10**

$$T = \left( \frac{Q \cdot n}{k_u \cdot S_x^{1.67} \cdot S_L^{0.5}} \right)^{.375}$$

Q	6.30 cfs
n	0.012
$k_u$	0.56
$S_x$	0.03
$S_L$	0.03
T	<b><u>8.19</u></b> ft

**CI-11**

$$T = \left( \frac{Q \cdot n}{k_u \cdot S_x^{1.67} \cdot S_L^{0.5}} \right)^{.375}$$

Q	1.75 cfs
n	0.012
$k_u$	0.56
$S_x$	0.02
$S_L$	0.02
T	<b><u>7.04</u></b> ft

**CI-12**

$$T = \left( \frac{Q \cdot n}{k_u \cdot S_x^{1.67} \cdot S_L^{0.5}} \right)^{.375}$$

Q	1.80 cfs
n	0.012
k <sub>u</sub>	0.56
S <sub>x</sub>	0.03
S <sub>L</sub>	0.03
T	<u>5.12</u> ft

**CI-13**

$$T = \left( \frac{Q \cdot n}{k_u \cdot S_x^{1.67} \cdot S_L^{0.5}} \right)^{.375}$$

Q	0.70 cfs
n	0.012
k <sub>u</sub>	0.56
S <sub>x</sub>	0.03
S <sub>L</sub>	0.03
T	<u>3.59</u> ft

**CI-14**

$$T = \left( \frac{Q \cdot n}{k_u \cdot S_x^{1.67} \cdot S_L^{0.5}} \right)^{.375}$$

Q	0.52 cfs
n	0.012
k <sub>u</sub>	0.56
S <sub>x</sub>	0.03
S <sub>L</sub>	0.03
T	<u>3.22</u> ft

**CI-15**

$$T = \left( \frac{Q \cdot n}{k_u \cdot S_x^{1.67} \cdot S_L^{0.5}} \right)^{.375}$$

Q	1.87 cfs
n	0.012
k <sub>u</sub>	0.56
S <sub>x</sub>	0.03
S <sub>L</sub>	0.03
T	<u>5.19</u> ft



**CI-16**

$$T = \left( \frac{Q \cdot n}{k_u \cdot S_x^{1.67} \cdot S_L^{0.5}} \right)^{.375}$$

Q	3.27 cfs
n	0.012
k <sub>u</sub>	0.56
S <sub>x</sub>	0.03
S <sub>L</sub>	0.03
T	<b><u>6.40</u></b> ft

**CI-17**

$$T = \left( \frac{Q \cdot n}{k_u \cdot S_x^{1.67} \cdot S_L^{0.5}} \right)^{.375}$$

Q	4.93 cfs
n	0.012
k <sub>u</sub>	0.56
S <sub>x</sub>	0.03
S <sub>L</sub>	0.03
T	<b><u>7.47</u></b> ft

## Diamond Estates Subdivision - CURB INLETS


10-YEAR STORM

Area #	Area	I	C	Weir			Required	Actual	
				Q (cfs)	Q=3.0LY <sup>1.5</sup> (cfs)	Y (ft)	L (ft)	L (ft)	
CI-1	0.80	7.20	0.50	2.88	2.88	0.49	<b>2.80</b>	<b>4</b>	4' box
CI-2	0.16	7.20	0.81	0.93	0.93	0.49	<b>0.91</b>	<b>4</b>	4' box
CI-3	0.66	7.20	0.81	3.85	3.85	0.49	<b>3.74</b>	<b>4</b>	4' box
CI-4	0.14	7.20	0.50	0.50	0.50	0.49	<b>0.49</b>	<b>4</b>	4' box
CI-5	0.58	7.20	0.81	3.38	3.38	0.49	<b>3.29</b>	<b>4</b>	4' box
CI-6	0.11	7.20	0.50	0.40	0.40	0.49	<b>0.38</b>	<b>4</b>	4' box
JB-2	0.01	7.20	0.50	0.04	0.04	0.49	<b>0.03</b>	<b>4</b>	4' box
CI-8	0.66	7.20	0.50	2.38	2.38	0.49	<b>2.31</b>	<b>4</b>	4' box
CI-9	0.12	7.20	0.81	0.70	0.70	0.49	<b>0.68</b>	<b>4</b>	4' box
CI-10	1.75	7.20	0.50	6.30	6.30	0.49	<b>6.12</b>	<b>7'-6"</b>	4' box with 3'-6" wing
CI-11	0.30	7.20	0.81	1.75	1.75	0.49	<b>1.70</b>	<b>4</b>	4' box
CI-12	0.50	7.20	0.50	1.80	1.80	0.49	<b>1.75</b>	<b>4</b>	4' box
CI-13	0.12	7.20	0.81	0.70	0.70	0.49	<b>0.68</b>	<b>4</b>	4' box
CI-14	0.09	7.20	0.81	0.52	0.52	0.49	<b>0.51</b>	<b>4</b>	4' box
CI-15	0.32	7.20	0.81	1.87	1.87	0.49	<b>1.81</b>	<b>4</b>	4' box
CI-16	0.56	7.20	0.81	3.27	3.27	0.49	<b>3.17</b>	<b>4</b>	4' box

**Diamond Estates Subdivision - Culvert Capacity**

ON SITE DRAINAGE

Pipe Name	From	To	Design Flow (cfs):	Slope (ft/ft):	Diameter (inches)	No. Pipes	Manning's	Area Full (sf)	Wetted Perimeter Full (ft)	Hydraulic Radius Full (ft)	Flow Capacity (cfs)	% Capacity
Pipe 56	CI-1	CI-2	2.88	0.0050	18	1	0.012	1.77	4.712	0.375	8.05	36%
Pipe 55	CI-2	FES-1	3.81	0.0100	18	1	0.012	1.77	4.712	0.375	11.38	34%
Pipe 7	CI-5	CI-3	11.48	0.0150	18	1	0.012	1.77	4.712	0.375	13.94	82%
Pipe 5	CI-4	FES-2	13.11	0.0200	18	1	0.012	1.77	4.712	0.375	16.09	81%
Pipe 6	CI-3	CI-4	12.30	0.0150	18	1	0.012	1.77	4.712	0.375	13.94	88%
Pipe 10	JB-2	CI-5	8.75	0.0100	18	1	0.012	1.77	4.712	0.375	11.38	77%
Pipe 9	CI-6	CI-5	0.64	0.0050	18	1	0.012	1.77	4.712	0.375	8.05	8%
Pipe 10(1)	CI-8	JB-2	8.75	0.0100	18	1	0.012	1.77	4.712	0.375	11.38	77%
Pipe 11	CI-9	CI-8	0.70	0.0050	18	1	0.012	1.77	4.712	0.375	8.05	9%
Pipe 47	CI-10	CI-8	8.05	0.0100	18	1	0.012	1.77	4.712	0.375	11.38	71%
Pipe 48	CI-11	CI-10	1.75	0.0050	18	1	0.012	1.77	4.712	0.375	8.05	22%
Pipe 45	CI-12	CI-13	1.80	0.0050	18	1	0.012	1.77	4.712	0.375	8.05	22%
Pipe 42	CI-15	CI-16	4.89	0.0050	18	1	0.012	1.77	4.712	0.375	8.05	61%
Pipe 46	CI-14	CI-13	0.52	0.0050	18	1	0.012	1.77	4.712	0.375	8.05	7%
Pipe 43	JB-1	CI-15	3.02	0.0100	18	1	0.012	1.77	4.712	0.375	11.38	27%
Pipe 41	CI-16	FES-3	8.16	0.0100	18	1	0.012	1.77	4.712	0.375	11.38	72%
Pipe 44(1)	CI-13	JB-1	3.02	0.0050	18	1	0.012	1.77	4.712	0.375	8.05	38%



BY:		REVISION:		DATE:	
<p><b>GNE</b> Designing our client's success  <b>GarNat Engineering, LLC</b>          P.O. Box 116 (72018) Ph (501) 408-4650          2909 Military Road Fx (888) 900-3068          Benton, AR 72015 gmatengineer@gmail.com</p>					
<p><b>FOR USE &amp; BENEFIT: DIAMOND DEVELOPMENT</b></p>					
<p><b>PRELIMINARY</b></p>					
<p>CONTENTS: <b>INLET BASIN MAP</b></p>					
<p>PROJECT NO: <b>21206</b></p>					
<p>DATE: <b>FEB 2023</b></p>					
<p>SHEET NO: <b>1.0</b></p>					

A:\Projects\2023\Project\21206\Diamond\Diamond.dwg, Rev. 2, Date: 02/02/2023, Project: 21206, Drawn: GNE, Checked: GNE, Date: 02/02/2023