

BISHOP AQUATIC CENTER HEAT/ENERGY BALANCE





Figure 2-2. SWHP SR System Schematic



Component Parameters/Conditions

Component

Description	Volume (cu ft)	Volume (gal)	Surface Area (sq ft)	Fluid Dens (lb/cu ft)	Total Mass (lb)	Average T (F)	Relative Hum RH
A Aquatic Building (Air Space)	192000		12750	0.0753	14,458	83	0.6

Relative Humidity Calculation

Date	Time	Dry Bulb Temp (F)	Wet Bulb Temp (F)	DB (Cel)	WB (Cel)	e(d)	e(w)	RH (%)	Dew Point Temp (F)	Sat Ratio (lbw/lba)	Sat Enth (BTU/lba)	Hum Ratio (lbw/lba)	Adj Enth (Btu/lb)	Est. TOTAL Enth (BTU)	Est. Imbalance from Ideal (BTU)	Comment	
Ideal Airspace Conditions according to PoolPAK																	
			82	71	27.8	21.7	37.3	25.9	58.2	66.9	0.02401	45.64727	0.01397	35.00957	506,154	-	IDEAL (According to PoolPak)
Inside Aquatic Center																	
	5/11/2022	7:05 AM	82	76	27.8	24.4	37.3	30.6	76.0	73.3	0.02401	45.64727	0.01824	39.69580	573,906	67,752	Roof Partially Open
	5/11/2022	12:25 PM	95	80	35.0	26.7	56.3	35.0	51.9	77.7	0.03706	63.86000	0.01925	44.03124	636,586	130,432	Roof Open
	5/12/2022	7:20 AM	85	76	29.4	24.4	41.1	30.6	66.2	72.8	0.02654	49.29547	0.01757	39.69961	573,961	67,807	Roof Closed
	5/12/2022	7:30 AM	80	76	26.7	24.4	35.0	30.6	83.3	74.0	0.02246	43.37491	0.01870	39.70460	574,033	67,879	Roof Partially Open
	5/12/2022	1:10 PM	95	82	35.0	27.8	56.3	37.3	57.5	79.7	0.03706	63.86000	0.02130	46.29365	669,295	163,141	Roof Open
	5/13/2022	7:10 AM	82	76	27.8	24.4	37.3	30.6	76.0	73.3	0.02401	45.64727	0.01824	39.69580	573,906	67,752	Roof Partially Open
	5/13/2022	1:00 PM	95	77	35.0	25.0	56.3	31.7	44.1	74.9	0.03706	63.86000	0.01633	40.81684	590,114	83,959	Roof Open
PoolPak Exhaust Air																	
	5/13/2022	1:10 PM	80	70	26.7	21.1	35.0	25.0	60.7	65.9	0.02245703	43.37491	0.01363511	34.15117	493,744	(12,410)	WHY ARE WE REJECTING?

Description	Volume (cu ft)	Volume (gal)	Surface Area (sq ft)	Ave Depth (ft)	Fluid Dens (lb/cu ft)	Total Mass (lb)	Desired Temp (F)	Measured Temp (F)	Enthalpy Change (BTU)	Enthalpy Chng (Ton)
B Lap Pool (72L x 66W)	33,420.23	250,000	4774	7.0	62.4	2,085,422	82	86	8,341,688	695.14

Relative Humidity Equation

$$e_d = 6.112 \cdot e^{\frac{17.502 + T_d}{240.97 + T_d}}$$

$$e_w = 6.112 \cdot e^{\frac{17.502 + T_w}{240.97 + T_w}}$$

C Thera Pool (55'Dia.) 5,881.96 44,000 1185 5.0 62.4 367,034 93 93 - -

$$e_w = 6.112 \cdot e^{\frac{240.97 + T_w}{T_w}}$$

$$\text{Relative Humidity} = \frac{e_w - N \cdot (1 + 0.00115 \cdot T_w) \cdot (T_d - T_w) + 100}{e_d}$$

e = 2.71828182845904
 T_d = Dry Bulb Temperature (Celsius)
 T_w = Wet Bulb Temperature (Celsius)
 N = .6687451584

Description	Heat Rate (BTU/hr)	Heat Rate (Ton)	Water Flow (GPM)	Heat Chng Pool (F/hr)
D Lap Pool Heater - Pentair	638,000	53.17		3.27
E Thera Pool Heater - Pentair	638,000	53.17		0.58

Description	Evap Coil Cap (BTU/hr)	Evap Coil (Ton)	Pool Cond (BTU/hr)	Evap Coil (Ton)	Supply Fan Air Density (ass Air Mass Flow (cfm) (lbs/cu ft)	Air Mass Flow (lbs/n Flow (bs/hr)
F PoolPak	719,000	59.92	850000	70.8	28000	0.0897 2511.6 150,696

Description
G PoolPak - Air Cooled Condenser

FLOW - Heat/Mass/Entergy Balance

Line	Description
1	Solar Radiance into Aquatic Center Air Space

Overall Thermal Transfer

1/4" Glass Single(Horizontal Summer) 0.862068966 BTU/ft^2-F-hr
 1/4" Glass Double (Horizontal Summer) 0.5 BTU/ft^2-F-hr

The instantaneous heat gain through transparent areas such as windows and skylights not in direct sunlight:
 q = UA(To - Ti)

Assuming half of the roof is not in direct sunlight: 12,750 sq ft/2 = 6375 sq ft
 Air Temperature Difference (inside - Outside) 30 Delta F

1/4" Glass Single (Farside Roof) q = 164,871 BTU/hr = 13.74 Tons
 1/4" Glass Double (Farside Roof) q = 95,625 BTU/hr = 7.97 Tons

If the window is in direct sunlight, a portion of the incident solar radiation will be transmitted through the glass
 The Instantaneous gain:
 q = A(Cs Fshg +U(To - Ti))

Fshg

Table 11.11
Typical Shading Coefficients

glass type	thickness	C _s
single		
regular sheet	3/32", 1/8"	1.00
regular plate	1/4"	.95
regular plate	3/8"	.91
heat absorbing sheet	7/32"	.71
heat absorbing plate*	1/4"	.67
	3/8"	.57
gray sheet	1/4"	.86
gray plate	1/4"	.70
double (up to 1/2" air space)		
both regular sheet	3/32", 1/8"	.90
both regular plate*	1/4"	.83

*Plate glass is sheet glass which has been ground and polished.

Table 11.12
Typical Solar Heat Gain Factors
 40° North latitude, July 21
 BTU/hr-ft²

time a.m.	time p.m.	a.m. orientation				horizontal
		N	E	S	W	
5	7	0	1	0	0	0
6	6	37	137	10	10	31
7	5	30	204	20	19	88
8	4	28	216	29	26	145
9	3	32	194	52	31	194
10	2	35	146	80	35	231
11	1	37	81	102	37	255
12	12	38	41	109	41	262

N W S E horizontal
p.m. orientation

Cs for Single 1/4" plate glass = 0.95 Fshg (40 deg July 21) = 216 BTU/hr-ft2
 Cs for Double 1/4" plate glass = 0.83

1/4" Glass Single (Direct side Roof) q = 1,504,896 BTU/hr = 125.41 Tons
 1/4" Glass Double (Direct side Roof) q = 1,337,348 BTU/hr = 111.45 Tons

Expected Heat Gain through Roof (Single plate glass) = 1,669,766 BTU/hr = 139.15 Tons
 Expected Heat Gain through Roof (Double plate glass) = 1,432,973 BTU/hr = 119.41 Tons

2 Roof Heat Rejection

3 Return Air to PoolPak

Description	Flow (Max Cap) (CFM)	Estimated Temp (F)	Estimated Rel Hum	Calc DB Temp (F)	Fluid Dens (lb/cu ft)	Total Mass (lb)	Desired Temp (F)	Measured Temp (F)	Enthalpy Change (BTU)	Enthalpy Chng (Ton)
Moist Air Back to PoolPak	28000	90	75							

4 Supplied Air from Pool Pak

Description	Flow (Max Cap) (CFM)	Estimated Temp (F)	Estimated Rel Hum	Calc DB Temp (F)	Fluid Dens (lb/cu ft)	Total Mass (lb)	Desired Temp (F)	Measured Temp (F)	Enthalpy Change (BTU)	Enthalpy Chng (Ton)
Dry Air to Aquatic Air Space	28000	84	60							