

Vernon Williams <garnatengineering@gmail.com>
To: George Wooden <georgewooden98@gmail.com>

Vernon J. Williams, P.E.
GarNat Engineering, LLC
Mailing Address: Physical Address:
P.O. Box 116 3825 Mt Carmel Road
Benton, AR 72018 Bryant, AR 72022
Ph: (501) 408-4650 Cell: (501) 425-2771
www.garnatengineering.com

----- Forwarded message -----

From: **Colton Leonard** <cleonard@cityofbryant.com>
Date: Mon, Nov 17, 2025 at 11:50 AM
Subject: Re: Can I get the DRC comments from yesterday for Bart's plot plan?
To: Vernon Williams <garnatengineering@gmail.com>

Sorry for the delay! Here are those comments.

Best,
Colton

1. 3492 Market Place Ave - site plan

Utilities

1. Submit full set of utility plans [No extensions required - Water and sewer mains added to plot plan](#)
2. What is the proposed building use? [Office / Retail lease space](#)
3. Show existing water main. Verify that the building footprint is not over the water line. The building cannot be on top of the water line.
Must remain 7.5' from the water line. [Plot plan updated](#)
4. Show connection of water and sewer services [Services added to plot plan](#)

Streets

1. No comments

Stormwater

[Per discussion w/ Troy Ellis we are disturbing 0.35 acres & no](#)

1. Small Scale ADEQ permit required and submitted to City of Bryant [SWPPP is required.](#)
2. NOC submitted to City of Bryant and posted on site [See response above](#)

Engineering

1. Handicap parking requires a sign [Sign added](#)
2. Show dimensions on handicap parking [Dimensions added](#)

3. Show parking lot counts and dimensions **Added**

Planning

1. There will be a need for an island with curbing at least for a portion along Progress Way to delineate the entrance for Progress Way and allow for a separation of the street entrance and the parking lot. Such as what was done across the street. **Island added**

Fire

1. Include a Knox Box near the main entrance at a height of 60" - 66". [AFPC, 506.1] **Will comply**

On Fri, Nov 14, 2025 at 9:32 AM Vernon Williams <garnatengineering@gmail.com> wrote:

Vernon J. Williams, P.E.
GarNat Engineering, LLC
Mailing Address: Physical Address:
P.O. Box 116 3825 Mt Carmel Road
Benton, AR 72018 Bryant, AR 72022
Ph: (501) 408-4650 Cell: (501) 425-2771
www.garnatengineering.com

**Colton Leonard, AICP**

Interim Director of Planning and Development

501-943-0301

cleonard@cityofbryant.com

www.cityofbryant.com

210 SW 3rd St, Bryant, AR 72022